

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60123054

Blatt *Sheet*
0001

| | | | |
|-------------------------------------|------------------------------------|--|--------------------|
| Ihr Zeichen <i>Client Reference</i> | Unser Zeichen <i>Our Reference</i> | Ausstellungsdatum <i>Date of Issue</i> | <i>(day/mo/yr)</i> |
| | 0001--27137816 001 | 28.08.2017 | |

Genehmigungsinhaber *License Holder*

SIGMA ELEKTRİK SAN. VE TİC.A.Ş.
YUNUS EMRE MAH.YENİDOĞAN YOLU CAD.
NO:30/A SANCAKTEPE-İSTANBUL
Türkiye

Fertigungsstätte *Manufacturing Plant*

SIGMA ELEKTRİK SAN. VE TİC.A.Ş.
YUNUS EMRE MAH.YENİDOĞAN YOLU CAD.
NO:30/A SANCAKTEPE-İSTANBUL
Türkiye

Prüfzeichen *Test Mark*



Regular Production
Surveillance
Safety
Type Approved

www.tuv.com
ID: 1111215854

Geprüft nach *Tested acc. to*
IEC 60898-1:2015

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Circuit Breaker

Type Designation: SMD10000

5

Trademark: Sigma
Number of Poles-rated voltage:

1P-230 VAC
1P+N- 230 VAC
2P- 230 VAC
3P-230/400 VAC
3P+N -230/400 VAC
4p-230/400 VAC

Rated Current: 2A, 4A, 6A, 10A, 16A, 20A, 25A, 32A
40A, 50A, 63A

Instantaneous tripping current: Type C

Rated short-circuit capacity: 10000

Method of mounting: Screw

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht. This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 <http://www.tuv.com/safety>

Zertifizierungsstelle



Sahure Giraldip

Zertifizierungsstelle