

## Zertifikat

## Certificate



Zertifikat Nr. Certificate No.  
R 60123060

Blatt Sheet  
0001

Ihr Zeichen Client Reference

Unser Zeichen Our Reference  
0001--27134424 001

Ausstellungsdatum  
28.08.2017

Date of Issue  
(day/mo/yr)

### Genehmigungsinhaber License Holder

SIGMA ELEKTRİK SAN. VE TİC.A.Ş.  
YUNUS EMRE MAH.YENİDOĞAN YOLU CAD.  
NO:30/A SANCAKTEPE-İSTANBUL  
Türkiye

### Fertigungsstätte Manufacturing Plant

SIGMA ELEKTRİK SAN. VE TİC.A.Ş.  
YUNUS EMRE MAH.YENİDOĞAN YOLU CAD.  
NO:30/A SANCAKTEPE-İSTANBUL  
Türkiye

### Prüfzeichen Test Mark



Regular Production  
Surveillance  
Safety  
Type Approved

www.tuv.com  
ID: 1111213851

Geprüft nach Tested acc. to  
IEC 60898-1:2015

Zertifiziertes Produkt (Geräteidentifikation)  
Certified Product (Product Identification)

Lizenzentgelte - Einheit  
License Fee - Unit

### Circuit Breaker

Type Designation: SMD6000

5

Trademark: Sigma

Number of Poles-rated voltage:  
1P-230 VAC  
1P+N- 230 VAC  
2P- 230 VAC  
3P-230/400 VAC  
3P+N -230/400 VAC  
4p-230/400 VAC

Rated Current: 2A, 4A, 6A, 10A, 16A, 20A, 25A, 32A  
40A, 50A, 63A

Instantaneous tripping current: Type C

Rated short-circuit capacity: 6000

Method of mounting: Screw

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com  
Fax: +49 221 806-3935 <http://www.tuv.com/safety>

